


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm					
NAME:		TYPE:		WEIGHT:	
SPEC.:		DIM.:		SERIAL No.:	
MFR.:		SUR.:28		Shielding Angle:	

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 83.04 lm/W
MODEL	ALRP35-6G30-M	I _{max} (cd)	2474	S/MH(C0/180)	0.40	
NOMINAL POWER(W)	6	LOR(%)	100.0	S/MH(C90/270)	0.39	
RATED VOLTAGE(V)	226	TOTAL FLUX(lm)	522.31	η UP,DN(C0-180)	0.0,49.7	
NOMINAL FLUX(lm)	522.306	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,50.3	
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	0.00	
TEST VOLTAGE(V)	225.1	η down(%)	100.0	CIBSE SHR MAX	1.00	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:AE
 Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:7.240m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	Φ lum, lamp
10	1560	1574	1563	1574	1605	1603	1602	1547	0- 10	191.9	191.9	36.7,36.7
20	240.2	267.9	252.0	269.9	293.3	280.6	270.6	228.5	10- 20	211.7	403.7	77.3,77.3
30	60.22	62.25	59.78	61.49	65.23	63.62	62.15	58.90	20- 30	54.96	458.6	87.8,87.8
40	27.35	27.61	28.32	29.80	29.45	29.15	29.16	29.00	30- 40	26.08	484.7	92.8,92.8
50	16.49	16.28	17.04	18.29	17.67	17.20	17.39	17.78	40- 50	17.15	501.8	96.1,96.1
60	8.913	9.047	9.079	9.790	9.594	9.117	9.087	9.415	50- 60	11.73	513.6	98.3,98.3
70	3.747	3.874	3.933	4.122	4.063	3.919	3.886	3.835	60- 70	6.220	519.8	99.5,99.5
80	0.7142	0.7530	0.8124	0.8240	0.7366	0.7181	0.6785	0.7023	70- 80	2.326	522.1	100,100
90	0.0626	0.0782	0.0978	0.0665	0	0	0	0	80- 90	0.1824	522.3	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:AE
 Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:7.240m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: AE
Test Date: 2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 7.240m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.12	1.10	1.08	1.10	1.08	1.07	1.06	1.05	1.03	1.03	1.01	1.00	.99	.98	.98	.96
2.0	1.06	1.03	1.01	1.05	1.02	.99	1.02	.99	.97	.99	.97	.95	.96	.95	.93	.92
3.0	1.01	.98	.94	1.00	.97	.94	.98	.95	.92	.95	.93	.91	.93	.91	.89	.88
4.0	.97	.93	.90	.96	.92	.89	.94	.91	.88	.92	.89	.87	.90	.88	.86	.85
5.0	.93	.89	.86	.92	.88	.85	.91	.87	.85	.89	.86	.84	.88	.85	.83	.82
6.0	.90	.85	.82	.89	.85	.82	.88	.84	.81	.87	.83	.81	.85	.83	.80	.79
7.0	.87	.82	.79	.86	.82	.79	.85	.81	.79	.84	.81	.78	.83	.80	.78	.77
8.0	.84	.80	.77	.84	.79	.77	.83	.79	.76	.82	.78	.76	.81	.78	.76	.75
9.0	.82	.77	.74	.81	.77	.74	.80	.77	.74	.80	.76	.74	.79	.76	.74	.73
10.0	.79	.75	.72	.79	.75	.72	.78	.75	.72	.78	.74	.72	.77	.74	.72	.71



C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:AE
 Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:7.240m [K=1.0000]
 Remarks:

WEC AND CCEC

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm					
NAME:		TYPE:		WEIGHT:	
SPEC.:		DIM.:		SERIAL No.:	
MFR.:		SUR.:28		Shielding Angle:	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.147	.084	.027	.141	.080	.025	.128	.074	.024	.117	.067	.022	.106	.062	.020	
2.0	.138	.075	.023	.132	.073	.022	.122	.068	.021	.112	.063	.020	.104	.059	.018	
3.0	.128	.068	.020	.124	.066	.020	.115	.062	.019	.107	.059	.018	.100	.055	.017	
4.0	.120	.062	.018	.116	.061	.018	.109	.058	.017	.102	.055	.017	.096	.052	.016	
5.0	.113	.057	.017	.109	.056	.016	.103	.054	.016	.097	.051	.015	.092	.049	.015	
6.0	.106	.053	.015	.103	.052	.015	.098	.050	.015	.093	.048	.014	.088	.046	.014	
7.0	.100	.050	.014	.098	.049	.014	.093	.047	.014	.089	.045	.013	.085	.044	.013	
8.0	.095	.046	.013	.093	.046	.013	.089	.044	.013	.085	.043	.012	.081	.042	.012	
9.0	.090	.044	.012	.089	.043	.012	.085	.042	.012	.081	.041	.012	.078	.040	.011	
10.0	.086	.041	.011	.085	.041	.011	.081	.040	.011	.078	.039	.011	.075	.038	.011	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.169	.158	.147	.145	.135	.127	.099	.093	.088	.057	.054	.051	.018	.017	.016	
2.0	.152	.133	.117	.130	.114	.101	.089	.079	.070	.051	.046	.041	.016	.015	.013	
3.0	.137	.113	.094	.118	.098	.082	.081	.068	.057	.047	.040	.034	.015	.013	.011	
4.0	.125	.098	.078	.107	.085	.067	.074	.059	.047	.043	.035	.028	.014	.011	.009	
5.0	.115	.086	.065	.098	.074	.056	.068	.052	.040	.039	.030	.024	.013	.010	.008	
6.0	.106	.076	.055	.091	.066	.048	.063	.046	.034	.036	.027	.020	.012	.009	.007	
7.0	.098	.068	.047	.084	.059	.041	.058	.041	.029	.034	.024	.017	.011	.008	.006	
8.0	.092	.061	.040	.079	.053	.035	.055	.037	.025	.032	.022	.015	.010	.007	.005	
9.0	.086	.056	.035	.074	.048	.031	.051	.034	.022	.030	.020	.013	.010	.007	.004	
10.0	.081	.051	.031	.070	.044	.027	.048	.031	.019	.028	.018	.011	.009	.006	.004	

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:AE
Test Date:2020-06-16

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:7.240m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm										
NAME:			TYPE:			WEIGHT:				
SPEC.:			DIM.:			SERIAL No.:				
MFR.:			SUR.:28			Shielding Angle:				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	16.2	16.9	16.5	17.1	17.3	16.4	17.1	16.7	17.3	17.4
3H	16.8	17.4	17.0	17.6	17.8	17.0	17.7	17.2	17.8	18.0
4H	16.9	17.5	17.2	17.7	17.9	17.1	17.8	17.4	18.0	18.2
6H	16.9	17.5	17.2	17.7	18.0	17.1	17.7	17.4	18.0	18.2
8H	16.9	17.4	17.2	17.7	17.9	17.1	17.7	17.4	17.9	18.2
12H	16.8	17.4	17.1	17.6	17.9	17.1	17.6	17.4	17.9	18.1
4H 2H	16.5	17.2	16.8	17.4	17.6	16.7	17.3	17.0	17.5	17.8
3H	17.2	17.7	17.5	18.0	18.2	17.4	17.9	17.7	18.2	18.4
4H	17.3	17.8	17.7	18.1	18.4	17.6	18.1	17.9	18.4	18.7
6H	17.4	17.8	17.7	18.1	18.5	17.6	18.0	18.0	18.4	18.7
8H	17.3	17.7	17.7	18.1	18.4	17.5	18.0	17.9	18.3	18.7
12H	17.3	17.6	17.7	18.0	18.4	17.5	17.9	17.9	18.2	18.6
8H 4H	17.3	17.7	17.7	18.1	18.5	17.5	18.0	17.9	18.3	18.7
6H	17.4	17.7	17.8	18.1	18.5	17.6	17.9	18.0	18.3	18.7
8H	17.3	17.6	17.8	18.0	18.5	17.5	17.8	18.0	18.3	18.7
12H	17.3	17.5	17.7	18.0	18.4	17.5	17.7	17.9	18.2	18.6
12H 4H	17.3	17.7	17.7	18.0	18.4	17.5	17.9	17.9	18.2	18.6
6H	17.3	17.6	17.8	18.0	18.5	17.5	17.8	18.0	18.2	18.7
8H	17.3	17.5	17.7	18.0	18.4	17.5	17.7	17.9	18.2	18.7
Variations with the observer position at spacings:										
S = 1.0H	+ 0.6 / - 0.9					+ 0.6 / - 0.8				
1.5H	+ 0.5 / - 0.5					+ 0.5 / - 0.5				
2.0H	+ 1.1 / - 1.3					+ 1.1 / - 1.3				

CIE Pub.117, 522.3 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = -2.3$)

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:AE
Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:7.240m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	87	81	77	87	80	77	86	80	77	73
0.80	94	89	85	94	88	85	93	88	84	81
1.00	99	93	90	98	93	89	96	93	89	85
1.25	103	98	94	102	97	94	100	96	93	89
1.50	106	101	97	104	100	97	102	99	96	91
2.00	108	104	101	107	103	100	104	101	99	93
2.50	110	106	103	108	105	102	105	103	100	94
3.00	112	108	105	110	107	104	106	104	102	96
4.00	114	111	109	112	109	107	108	106	105	97
5.00	115	113	111	113	111	109	109	107	106	99
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:AE
Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:7.240m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: AE
Test Date: 2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 7.240m [K=1.0000]
Remarks:

AAI Figure

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:AE
 Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:7.240m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: AE
 Test Date: 2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.362
 Humidity: 65.0%
 Test Distance: 7.240m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:225.1V I:0.0310A P:6.290W PF:0.8830 Freq:50.00Hz Lamp Flux:522.306x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:28	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	5811
L_0~180(75)av	3367
L_0~180(85)av	274
L_90~270(65)av	5814
L_90~270(75)av	3376
L_90~270(85)av	319
L_45(65)av	5958
L_45(75)av	3395
L_45(85)av	215

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 15.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:AE
 Test Date:2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
 Humidity:65.0%
 Test Distance:7.240m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 15.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: AE
Test Date: 2020-06-16

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity: 65.0%
Test Distance: 7.240m [K=1.0000]
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:7.240m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.362
Humidity:65.0%
Test Distance:7.240m [K=1.0000]
Remarks:

```